1.0 1.1 2.0 2.2 3.0	machine connection: drain connection hose, DN 22 hose fitted as odour trap in interior of machinedrain (max. 700 mm above finished floor level), DN 50Machine connection: fresh water supply, G 3/4"Soft cold water 10°C, DN 15, G 3/4 a max. 0,54 mmol/I CaCO ₃ (max. 3°dH)Flow rate: 3 l/min Minimum flow pressure: 60 kPa / 0,6 bar in front of solenoid valve Maximum pressure: 500 kPa / 5,0 bar stopcock and fine screen $\leq 25 \mu m$ Machine connection: electrical connection cable 3G 2,5 mm²			820 830 - 855		0 0 0 0 0	450 432 432 432
3.1	electricity supply to the machine: 1N PE 230V ~ 50Hz nominal current / - capacity: 15,7 A / 2,9 kW Fuse protection: 16 A	×260 80	600 80	10 - 35		50 55	
6.1 all cat	Heat load of warewash area for 20 programme cycles/h total 2,1 kW, perceptible 1,4 kW, latent 0,7 kW bles, pipes etc leaving machine 1,6 m bition of the connection piping can also be mirror-inverted!	1.1					
(A) Er Final i	chine Equipment http://www.analysian.com/ance/analysian.com/analysian.c			600			3.0-1.0
		MEIKO MIDDLE GoldDiamond Pa	EAST FZE *k, Building#6, office #/	206	Revision Reference		Type M-ICLEAN UM+
		P.O. Box 282365, U.A.EDubai Phone +971 43 41 51 72 E-MAIL: wat@meiko.de This drawing may not be neither passed to third parties for their information or copied or used for competitive purposes without our consent. All rights reserved. We reserve the right to make changes resulting from technical progress. This drawing was computer generated and is not subject to the checking and any release process; it is also not subject to change management. Please note:			TYPE: CROCKERY		G Order-No.
	25462.2.5 RIGHT by MEIKO	This document is only valid in conjunction wit Sheet "Important Information". These can be downloaded from the Partnernet.			Scale 1:25 AFG	drawn: 15.08.2020 m-iplan	checked: 15.08.2020 m-iplan ©COPYRIGHT

1:25 AFG

EN

COPYRIGHT by MEIKO